

**Forks Municipal Water
City of Forks
2015
Report to Consumers on Water Quality**

Dear Customer: We are pleased to present a summary of the quality of the water provided to you during the year 2015. The Safe Drinking Water Act (SDWA) requires that utilities issue an annual "Consumer Confidence" report to customers in addition to the other notices that may be required by law. This report details where our water comes from, what it contains, and the risks our water testing and treatment are designed to prevent. Forks Municipal Water is committed to providing you with a safe and reliable supply of water. Informed consumers are our best allies in maintaining safe drinking water.

The bottom line: Does Forks City water meet all federal and state regulations for drinking water? Absolutely.

We encourage public interest and participation in our community's decisions affecting drinking water. Regular city council meetings occur on the second and fourth Mondays of each month, at city hall at 7:30 p.m. The public is welcome. Find out more about Forks Municipal Water on the Internet at [www.forkswashington.com].

Overview

In 2015 Forks Municipal Water distributed a little more than 181 million gallons of water in the Forks area. Thank you for your part in conserving water.

Our water comes from 5 wells, which are located from the Forks water compound at 300 Lupine Ave. to the radio station. Our water as pumped from the ground passes all state health standards for potable water. To insure that it stays clean and safe, we add a very small amount of chlorine to kill any bacteria that could enter the system accidentally such as during a water main break or a back flow situation. Chlorinated systems are required to maintain just a trace of chlorine through out the distribution system. We try to maintain a minimum of .2-ppm chlorine, which is comparable to one inch in 80 miles or one minute in ten years. In addition we take at least 5 routine water samples per month and have them tested at an accredited lab for microbes such as total coliform, fecal coliform, and E-coli, contamination.

The water we pump from the ground has a .1 mg/L to.2 mg/L of natural fluoride. The City raises the fluoride level in the water to approximately 1 mg/L to help children grow healthy strong teeth. We test the fluoride level in the water at least 2 times each work day and we send 2 water samples to an accredited lab each month to be sure we are in compliance with all federal and state regulations for fluoride.

Once every nine years we send water to an independent lab and have it tested for at least 24 inorganic chemicals such as nickel, iron, and sodium. Every three years we test for over 60 volatile organic chemicals that are trihalomethanes such as styrene, chloroform, and butylbenzene and for 45 synthetic organic compounds such as naphthalene, pyrene, and PCB's. Every year we also test for nitrate contamination in the water. Chlorine and fluoride levels are monitored every workday in two different locations. Results from our latest testing are reflected in the tables below.

In the summer of 2015 the Forks Water Department took water samples from 20 homes and had it tested for Lead and Copper content. All of the samples passed easily. We have no lead water mains or service lines in our system. All new brass parts purchased in the last several years are made of no lead brass.

Water Trivia from USA BlueBook Operator's Companion 10th edition page 206

- It requires approximately 4 gallons of water to process a pound of hamburger.
- It takes 1,500 gallons of water to make one barrel of beer.
- About 39,000 gallons of water are used to manufacture a new car.
- There are about 17 million households in the U.S. that use water from private wells.
- An average residence in the U.S. uses 107,000 gallons per year.
- The average daily cost of public water supply is 25 cents per person.
- Of all the earth's water, 97% is in the oceans, 2% is frozen, and 1% is suitable for drinking.
- A human can survive for about a month without food, but can live only about a week without water.

How to Read This Table

The table below shows the results of our water-quality analyses for the last five years after testing for over 175 contaminants. Every regulated contaminant that we detected at or above the SRL in the water is listed here. The table contains the name of each substance, the highest level allowed by regulation (MCL), the ideal goals for public health, (MCLG), the amount detected, the usual sources of such contamination, footnotes explaining our findings, and a key to units of measurement. Definitions of MCL, and MCLG are important.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Minimum Detection Level or MDL: The minimum level of a contaminant at or above which the testing laboratory must report detection.

Key To Table

- AL = Action Level
- MCL = Maximum Contaminant Level
- MCLG = Maximum Contaminant Level Goal
- MDL=Minimum Detection Level
- MFL = million fibers per liter
- ppm = parts per million, or milligrams per liter (mg/l)
- ppb= parts per billion, or micrograms per liter
- SRL = State Dept. of Health minimum reporting level

Contaminant	Date Tested	Unit	MCL	MCLG	Amount Detected	SRL	Major Sources	Violations
Inorganic Contaminants								
1.Fluoride, F	3/12/12	ppm	4	4	2	.5	Erosion of natural deposits; Additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.	NO

Water Quality Table Footnote

1. Some people who drink water containing fluoride in excess of the MCL of 4 mg/L, for many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

OVER

Unregulated Contaminants

Forks Municipal Water did not test for Radon

NOTE

Please do not plant trees or large shrubs over water mains or near water meters. We have had numerous water main breaks due to tree roots. These problems are costly and time consuming and often result in damage to lawns and other landscaping.

Required Additional Health Information

To ensure that tap water is safe to drink, EPA prescribes limits on the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

(A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

(B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

(C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.

(D) Organic chemical contaminants, including synthetic and volatile organics which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

(E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791). This report was prepared by the Forks Water Dept. For more information, call Forks Municipal Water at (360) 374-5412. Learn more about the Forks Municipal Water system at [www.forkswashington.com].

Este informe contiene informacion muy importante. Traduscalo o hable con alguien que lo entienda bien.

The Forks area is experiencing record low precipitation and the City water supply is nearing cautionary levels. We are asking residents to voluntarily conserve water at this time.

Please visit the Washington State Department of Ecology website for a list of easy ways you can conserve water. <http://www.ecy.wa.gov/programs/wr/ws/wtrcnsv.html>