

CITY OF FORKS, WASHINGTON

ADDENDUM NO. 1

Forks Industrial Park – PUD Electrical Extension Trenching, Boring & Backfill Project

Addendum Date:	April 14, 2026	Addendum No.:	1
Project:	Forks Industrial Park – PUD Electrical Extension Trenching, Boring & Backfill Project		
Bid Opening:	Friday, April 24, 2026 at 2:00 PM – City of Forks City Hall, 500 East Division Street, Forks, WA 98331		
Issued By:	Rod Fleck, City Attorney/Planner (360) 374-5412, Ext. 111 rodf@forkswashington.org		

NOTICE TO ALL BIDDERS: This Addendum is hereby made part of the Bid Documents and shall take precedence over any conflicting provisions of the original Bid Package. Bidders shall use the **Revised Bid Form issued with this Addendum** in lieu of the Bid Form included in the original Bid Package. Bidders shall acknowledge receipt of this Addendum on the Revised Bid Form. Failure to submit the Revised Bid Form or to acknowledge receipt of this Addendum may render a bid non-responsive.

SECTION A – CLARIFICATIONS TO BID DOCUMENTS

Item A-1: Conduit Quantity and Size — All Trench and Bore Locations

Clallam County PUD has confirmed that the electrical installation will consist of **three (3) 3-inch conduits** installed in all trenched and bored sections throughout this project. This clarification applies to all references to "conduit" throughout the Bid Package and Project Map, and is reflected in the Revised Bid Form issued with this Addendum.

Item A-2: Minimum Trench Width Revision

The minimum trench width specified in Section 3 (Trench Excavation) of the Project Description is revised as follows:

Applies To	Original Specification	Revised Specification
All open-cut trench sections	Minimum 18 inches wide	Minimum 24 inches wide (or as directed by PUD — confirm with PUD prior to bid)

Note: The revised 24-inch minimum accommodates three 3-inch conduits with standard 3-inch spacing between conduits and 3-inch clearance from each trench wall. Bidders shall confirm the exact trench width requirement with PUD prior to submitting their bid. Any PUD-directed trench width greater than 24 inches shall be considered incidental to the trench excavation unit price; no additional compensation will be allowed.

Item A-3: Horizontal Directional Boring — Three Individual Bores per Crossing

PUD has confirmed that the boring method at both roadway crossings will consist of **three (3) individual bores per crossing**, each of sufficient diameter to accommodate one (1) 3-inch conduit. The original Bid Form items for boring (Items 11 and 12) are superseded by the Revised Bid Form issued with this Addendum, which reflects this configuration. Bidders shall price boring on a per-linear-foot basis for three individual bores at each crossing.

Item A-4: Project Map Title Correction

Throughout the Bid Package, all references to "PUD MAP" and "Exhibit A" are revised to read "PROJECT MAP." This correction applies to the following locations:

- Project Description, Section 1 (Project Overview) – Exhibit A reference
- Project Description, Section 3 (Trench Excavation) – "PUD MAP" reference
- The map exhibit title itself – from "Exhibit A" to "PROJECT MAP"

SECTION B – REVISED BID FORM

A **Revised Bid Form** is issued with this Addendum and is attached hereto. The Revised Bid Form supersedes the Bid Form included in the original Bid Package in its entirety. Bidders must submit the Revised Bid Form with their bid. The Revised Bid Form incorporates the following changes:

- Updated trench excavation line item quantities and descriptions to reflect three (3) 3-inch conduits and 24-inch minimum trench width (Item 5)
- Boring items revised to reflect three (3) individual bores per crossing, priced per linear foot (Items 11 and 12)
- Addendum acknowledgment block added to confirm receipt of Addendum No. 1

Bidders must not use the Bid Form from the original Bid Package. Only the Revised Bid Form attached to this Addendum will be accepted. Bids submitted on the original Bid Form will be considered non-responsive.

ADDENDUM ACKNOWLEDGMENT

Bidders must acknowledge receipt of this Addendum in the space provided on the Revised Bid Form. Failure to acknowledge receipt may render a bid non-responsive.

Issued by:

Rod Fleck, City Attorney/Planner
City of Forks

Date:

— END OF ADDENDUM NO. 1 —

See attached Revised Bid Form — Addendum No. 1. All other Bid Package provisions remain in full force and effect.